



NOTE:

1. GROUND FLOOR APPLICATIONS AND ALL FACADES EXPOSED TO ABNORMAL STRESS, HIGH TRAFFIC, OR DELIBERATE IMPACT HAVE THE BASE COAT REINFORCED WITH MESH PRIOR TO STANDARD MESH. LOCATION OF HIGH IMPACT ZONES SHOULD BE INDICATED ON CONTRACT DRAWINGS.

2. FLASHING TAPE SURFACE CONDITIONER AND FLASHING TAPE MAY BE USED IN LIEU OF FLASHING SYSTEM.

3. DETAIL DOES NOT APPLY TO CANTILEVERED DECKS. CANTILEVERED DECKS REQUIRE JOB SPECIFIC FLASHING DETAILS.

NOTE:

DETAIL ADDED TO PLAN SET ON SHEET AS302

15

TERMINATION AT WOOD FRAMED DECK



Department of
Veterans Affairs

DETAIL TITLE / RENOVATE_BLDG._110_EXTERIOR
DETAIL_15/AS302
TERMINATION_AT_DECK

SCALE :N.T.S.

DATE ISSUED: 06/01/2016

CAD DETAIL NO.: DETAIL_NO.